

SS8/2 – Platform, Low-speed and Service Lifts

Specified System Description

System Status

New

Modified

Removed

System Type

Platform Goods Lift

Dumb Waiter

Book Hoist

Vehicle Stacking Systems

Stage Lifts

Other (*specify*):

Drive Type

Electric

Hydraulic

Other (*specify*):

System Interfacing

SS2

Other (*specify*):

Not applicable

Standards

Performance / Installation Standards

NZS 4334:2012 Platform lifts and low-speed lifts.

BS EN 81-20:2020 Safety rules for the construction and installation of lifts. Lifts for the transport of persons and goods. Passenger and goods passenger lifts.

BS EN 81-20:2014 Safety rules for the construction and installation of lifts. Lifts for the transport of persons and goods. Passenger and goods passenger lifts (as modified by D2/AS1 - Second Edition, Amendment 7, Jan 2017).

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so (*Details provided*)

Other: (*specify*)

Inspection Standards

NZS 4334:2012 - Appendix A.

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (*Details provided*)

Other: (*specify*)

Maintenance Standards

NZS 4334:2012 - Appendix A.

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so (*Details provided*)

Other: (*specify*)

Inspections, Maintenance and Reporting

Minimum Inspection and Maintenance Procedures

Regular inspection, testing, planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard/document to ensure loading and unloading provisions are safe.

Inspection and Maintenance - Frequency and Responsibility

Depending on the type of installation and its performance standard

Annually: by IQP

Standard / Other document (specify)

Inspections and Maintenance for Interfaced Systems

Annual Inspection: by IQP

The system is connected to the building's emergency warning system therefore testing of the interface between the two systems will be carried out annually.

The system is NOT connected to the building's emergency warning system.

Reporting:

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out including dates, works undertaken, faults found, remedies applied and the name of the person who performed the work.
- Form 12A provided annually by the IQP