

SS 14/2 – Signs Relating to Specified Systems 1-13

Specified System Description

System Status

New

Modified

Removed

System Type

SS 1 – Signs for Automatic Systems for Fire Suppression

SS 2 – Sign for Automatic or Manual Emergency Warning Systems for Fire or other Dangers

SS 3/1 – Sign for Automatic Doors

SS 3/2 – Sign for Access Controlled Doors

SS 3/3 – Sign for Interfaced Fire or Smoke Doors or Windows

SS 4 – Sign for Emergency Lighting Systems

SS 6 – Sign for Riser Mains

SS 7 – Sign for Automatic Backflow Preventers

SS 8/1 – Sign for Passenger Carrying Lifts

SS 8/2 – Sign for Platform, Low-speed and Service Lifts

SS 8/3 – Sign for Escalators and Moving Walks

SS 10 – Sign for Building Maintenance Units

SS 11 – Sign for Laboratory Fume Cupboards

SS 12/1 – Sign for Audio Loops

SS 12/2 – Sign for FM Radio Frequency Systems and Infrared Beam Transmission Systems

SS 13/1 – Signs for Mechanical Smoke Control

SS 13/2 – Sign for Natural Smoke Control

SS 13/3 – Sign for Smoke Curtains

Other: (specify)

Standards

Performance / Installation Standards

F8/AS1 Acceptable Solution for Clause F8 – Signs (Second Edition, Amendment 4, Jan 2017).

F8/AS1 Acceptable Solution for Clause F8 – Signs (Second Edition, Amendment 3, Feb 2014).

F8/AS1 Acceptable Solution for Clause F8 – Signs (Second Edition, Amendment 2, Apr 2012).

F8/AS1 Acceptable Solution for Clause F8 – Signs (First Edition, Amendment 1, Sep 1993).

F8/AS1 Acceptable Solution for Clause F8 – Signs (First Edition, Jul 1992).

Signage as required by Nominated Performance/Installation Standard for the given Specified System 1-13. *(specify for all systems)*

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. *(Details provided)*

Other: *(specify)*

Inspection Standards

Inspection procedures in accordance with the details on pages 53 - 54 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (Amendment 3, Feb 2014).

Inspection procedures in accordance with the details on pages 53 - 54 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (Amendment 2, Oct 2011).

Inspection procedures in accordance with the details on pages 53 - 54 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (First Edition, May 2007 and Amendment 1, March 2008 Inc.).

Inspection for signages as required by nominated performance/installation standard and inspection standard for the given specified system 1-13. *(specify for all systems)*

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. *(Details provided)*

Other: *(specify)*

Maintenance Standards

Maintenance procedures in accordance with the details on pages 53 - 54 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (Amendment 3, Feb 2014).

Maintenance procedures in accordance with the details on pages 53 - 54 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (Amendment 2, Oct 2011).

Maintenance procedures in accordance with the details on pages 53 - 54 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (First Edition, May 2007 and Amendment 1, March 2008 Inc.).

Maintenance for signages as required by nominated performance/installation standard and maintenance standard for the given specified system 1-13. *(specify for all systems)*

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. *(Details provided)*

Other: *(specify)*

Inspections, Maintenance and Reporting

Minimum Inspection and Maintenance Procedures

Regular inspection, testing, planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard/document of the associated system to ensure signs remain correctly positioned, and legible and where appropriate ensure the escape route is identified.

Inspection and Maintenance - Frequency and Responsibility

Depending on the type of installation and its performance standard:

Daily by Owner (for Crowd Activities Risk group / Purpose groups CS, CL, CO, CM)

Annually by IQP

Monthly by Owner (for other Risk groups / Purpose groups)

Annually by IQP

Standard / Other document: *(specify)*

Reporting:

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out including dates, works undertaken, faults found, remedies applied and the name of the person who performed the work.
- Form 12A provided annually by the IQP.