

SS 15/2 – Final Exits

Specified System Description

System Status

New

Modified

Removed

System Type

All Final Exits on Escape Route giving Direct Access to a Safe Place

Other (*specify*):

System Interfacing

SS2

SS 3/1

SS 3/2

Other (*specify*):

Not applicable

Standards

Performance / Installation Standards

C/AS2 Acceptable Solution for Buildings other than Risk Group SH (Amendment 2, Nov 2020).

C/VM2 Verification Method: Framework for Fire Safety Design (Amendment 6, Nov 2020).

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so (*Details provided*)

Other: (*specify*)

Inspection Standards

Inspection procedures in accordance with the details on pages 49 - 50 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (Amendment 3, Feb 2014)).

Inspection procedures in accordance with the details on pages 49 - 50 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (Amendment 2, Oct 2011)).

Inspection procedures in accordance with the details on pages 49 - 50 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (First Edition, May 2007 and Amendment 1, March 2008 Inc.)).

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (*Details provided*)

Other: (*specify*)

Maintenance Standards

Maintenance procedures in accordance with the details on pages 49 - 50 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (Amendment 3, Feb 2014)).

Maintenance procedures in accordance with the details on pages 49 - 50 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (Amendment 2, Oct 2011)).

Maintenance procedures in accordance with the details on pages 49 - 50 in the Compliance Schedule Handbook (Authored by Ministry of Business, Innovation and Employment (First Edition, May 2007 and Amendment 1, March 2008 Inc.))

Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so (*Details provided*)

Other: (*specify*)

Inspections, Maintenance and Reporting

Minimum Inspection and Maintenance Procedures

Regular inspection, testing, planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard/document to ensure the occupants are not prevented from leaving the building in the event of an emergency.

Inspection and Maintenance - Frequency and Responsibility

Depending on the type of installation and its performance standard:

Daily by Owner (for Crowd Activities Risk group / Purpose groups CS, CL, CO, CM)

Annually by IQP

Monthly by Owner (for other Risk groups / Purpose groups)

Annually by IQP

Standard / Other document (*specify*):

Inspections and Maintenance for Interfaced Systems

Annual Inspection by IQP

The system is connected to other specified systems, therefore testing of the interface between the two systems will be carried out annually.

The system is NOT connected to other specified systems.

Reporting:

The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include:

- Details of any inspection, test or preventative maintenance carried out including dates, works undertaken, faults found, remedies applied and the name of the person who performed the work.
- Form 12A provided annually by the IQP.

Record No: 22209244
Date: 31 January 2023